



CITY OF DOVER SEWER SERVICE CONNECTION INSPECTION REPORT

DATE: _____

In Flood Zone yes no

ADDRESS _____

INSPECTION:

	N / A	Approved	Date	Signature of Inspector
Setbacks				
5 feet from the building foundation				
100 feet from a public well				
50 feet from a private well				
50 feet from surface water				
5 feet from a property line				
2 feet from seasonal high water level ¹				
Septic Tank baffles				
Locate wire				
Main line connection				
Septic tank outlet connection				
Septic tank inlet connection				
Curb stop ² (Riser labeled "SEWER")				
Tank set level				
Risers and riser connections				
Pump and related plumbing				
Pump check valve				
Second check valve: At curb stop _____ At tank wall _____				

¹ Tank located as shown on Engineering approved plans

² City staff will open when inspections are complete and installation accepted

City Use Only

Check one box for each trip

<input type="checkbox"/>																			
--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------	--------------------------

NOTES: _____

FINAL ACCEPTANCE: yes

Date: _____

Authorized City Agent: _____
print name

Signature: _____